

OBHARAT COKING COAL LIMITED
(A SUBSIDIARY OF COAL INDIA LIMITED)
OFFICE OF THE CHIEF GENERAL MANAGER
P.O.KUSUNDA (DHANBAD)

Ref.No.BCCL/AVI/E&M/2010-11/ 1289

Dated 15.11.2010

TENDER NOTICE.

Sealed tenders are hereby invited from experienced, reliable and financially sound contractors in two parts i.e. Technical Bid as part-I and Price bid as part-II for the work mentioned below:-

Name of the work	Cost of Tender Paper.	Estimated Cost (Rs.)	Earnest Money	Time of completion
Supply & installation of Earth Leakage Relay Through Restricted Neutral System with all Accessories at surface & underground switch Gear of III seam Godhur Colliery and Dhansar I to IV seam of Kusunda Area.	Rs.500/-	767135/-	1% of the estimated cost.	Within 60 days.

TERMS & CONDITIONS

1. The tender paper can be had from the office of the undersigned on any working days on Production of money receipt for Rs.500/- (Rupees five hundred) only non-refundable. The Last date of issue of tender paper will be on 29.11.2010.
2. Tenders will be received up to 3.00 P.M. on 02.12.2010 in the office of the undersigned and the same will be opened on same day at 3.30 P.M. in presence of the tenderers or their authorised representative in the office of the Addl.G.M., Kusunda Area.
3. The Earnest Money @ 1% of the estimated cost value should be deposited alongwith the Tender offer in the form of Demand Draft drawn on State Bank of India, Dhanbad in favour Of Bharat Coking Coal Limited, payable at Dhanbad or in cash.
4. The cash for earnest money will be accepted by the Area Finance Manager, Kusunda Area from 9.30 A.M. to 4.00 P.M. on all working days other than Saturdays. On Saturdays the cash will be accepted from 9.30 A.M. to 12.30 P.M.
5. Tenders not accompanied with the earnest money receipt will not be considered. The Earnest money of unsuccessful tenderers will be refunded without any interest and the Earnest money of successful tenderer will also not carry any interest and will be converted in to security money.

Contd.P/2

::2::

6. Average annual financial turnover during the last 03 years, ending 31st March of the previous Financial year should be at least 30% of the estimated cost.
7. Experience of having successfully completed similar works during last 07 years ending last day of month previous to the one in which applications are invited should be either of the following:-
 - a) Three similar completed works each costing not less than the amount equal to 40% of the estimated cost.

OR

- b) Two similar completed works each costing not less than the amount equal to 50% of the estimated cost.

OR

- c) One similar completed work costing not less than the amount equal to 80% of the estimated cost.

NOTE:- (Similar work means Electrical Control Tripping System for earth leakage relay.)

8. The offer of the intending bidders should be valid for 120 days.
9. The license of the tenderers to be submitted with their offer.
10. Affidavit to be submitted, for detail, contact AM(E&M),Kusunda Area.
11. Tenderers should submit Xerox copy of PAN Card, VAT/TIN No.
12. The tenderers should submit their experience certificate and valid income tax certificate.
13. The tender committee reserves the right to reject any or all the tenderers on part or in full Without assigning any reason whatsoever.
14. Banking detail as per format for e-payment.
15. Guarantee – six months.

C.C.TO:-

Area Manager(E&M)
Kusunda Area.

1. CGM(E&M),BCCL, Koyla Bhawan.
2. C.G.M. Kusunda Area.
3. C. V.O., Koyla Bhawan.
4. A.G.M., Kusunda Area.
5. GENERAL MANAGER (SYSTEM),Koyla Bhawan- For logging of CD & tender document on Website.
6. P.R.O,Koyla Bhawan – For publication on leading news paper & local news paper.
7. A.F.M., Kusunda Area.
8. All Area Manager(E&M), of BCCL.
9. All Project Offers, Kusunda Area.
10. Notice Board, Kusunda Area.

ABSTRACT

A) At No.1 pit, II, III & IV seam of Dhansar Colliery, Kusunda Area	Qty.	Unit Rate	Total Amount
1) Total cost of incorporation of 750 MA Electronic Earth Leakage Relay through Restricted Neutral System on the secondary Side of 11KV/550Volt surface Transformer as per the detail given in enclosed Annexure-I	02 Nos.		
2) Total cost of incorporation of graded Electronic Earth Leakage Relay in 550 Volt, FLP ACB/Starter/ G.E. Boxes as per the details given in enclosed Annexure-II	20 Nos.		
B) At 26 No. 3 seam Godhur Colliery of Kusunda Area.			
3) Total cost for incorporation of 750 MA Electronic Earth Leakage Relay through Restricted Neutral System on the secondary Side of 11KV/550 Volt surface Transformer as per the detail given in enclosed Annexure-III	01 No.		
4) Total cost for incorporation of graded Electronic Earth Leakage Relay in 550 Volt FLP/Starter/ G.E. Boxes as per the detail given in enclosed Annexure-IV.	12 Nos.		

AREA MANAGER(E&M)
KUSUNDA AREA.

ANNEXURE-I

For incorporation of 750 MA Electronic Earth Leakage Relay through Restricted Neutral System on the secondary side of 01 No. 11KV/550 Volt Transformer (surface) of No.1 pit, II, III, & IV seam of Dhansar Colliery, Kusunda Area.

Sl. No.	Description	Qty.	Unit Rate	Total Amount
01	Electronic Earth Leakage Relay of range 50 to 750 MA Having time setting at 100 M.Sec. to 1.0 Sec. and Aux, Supply 12V to 550 Volt & NO + NC.	01 No.		
02	CBCT for above ElectronicEarth Leakage Relay suitable For 550 Volt application.	01 No.		
03	Overcurrent & short circuit relay with delay arrangement.	01 No.		
04	C.T for O/C & S/C relay for HT application.	03 Nos.		
05	Neutral resistance monitoring relay.	01 No.		
06	Neutral resistance for 1000 KVA Transformer.	01 No.		
07	Amperemeter with CT.	01 Set.		
08	Test Reset knobs with contacts.	01 Set.		
09	Indicating Lamp with Bulb and Holder.	02 Sets.		
10	Fuse base with carrier.	02 Sets.		
11	Controls wiring kit with all accessories.	01 Set.		
12	Service & Hardware Kit.	01 Set		
13	Primary side NO Volt Coil.	01 No.		
14	Sheet steel box of size 500mm x 500mm x 200mm with Door including painting for mounting components at Surface Transformer with PVC conduit pipe for ducting.	01 Set.		
15	Installation, testing & commissioning.	01 Set.		

Area Manager(E&M)
Kusunda Area.

ANNEUXRE-II

For supply & installation of graded Electronic Earth Leakage Relay on
01 No. 550 Volt, FLP ACB/Starter/G.E Box of No.1 pit, II, III & IV Seam
at Dhansar Colliery, Kusunda Area.

Sl. No.	Description	Qty.	Unit Rate	Total amount
01	Electronic Earth Leakage Relay of range 50 to 750 MA With time setting 100 M.Sec to 1.0 Sec having Aux, Supply 12V to 550 Volt & NO + NC.	01 No.		
02	CBCT for above Electron ic Earth Leakage Relay Suitable for 550V. application.	01 No.		
03	Amperemeter with CT.	01 Set.		
04	Test Reset knobs with contacts.	01 Set.		
05	Indicating Lamp with Bulb and Holder.	02 Sets.		
06	Fuse base with carrier.	02 Sets.		
07	Microswitch with Duel point.	01 Set.		
08	Service & Hardware kit.	01 Set.		
09	Installation, testing & commissioning.	01 No.		

Area Manager (E&M)
Kusunda Area.

ANNEXURE-III

For incorporation of 750 MA Electronic Earth Leakage Relay through Restricted Neutral System on the secondary side 11KV/550 Volt Transformer (surface) at 26 No., 3 seam of Godhur Colliery, Kusunda Area.

Sl. No.	Description	Qty.	Unit Rate	Total Amount
01	Electronic Earth Leakage Relay of range 50 to 750 MA Having time setting at 100 M.Sec. to 1.0 Sec. and Aux, Supply 12V to 550 Volt & NO + NC.	01 No.		
02	CBCT moulded Resin cast for earth leakage relay Suitable for 550 Volt application.	01 No.		
03	Overcurrent & short circuit relay with delay Arrangement.	01 No.		
04	C.T. for O/C & S/C relay for HT application.	03 Nos.		
05	Neutral Resistance Monitoring Relay.	01 No.		
06	Neutral Resistance for 1000 KVA Transformer.	01 No.		
07	Amperemeter with CT	01 No.		
08	Test Reset knobs with contacts.	01 Set.		
09	Indicating lamp with Bulb and Holder.	02 Sets.		
10	Fuse base with carrier.	02 Sets.		
11	Control wiring kit with all accessories.	01 Set.		
12	Service & Hardware kit.	01 Set.		
13	Primary side no volt coil.	01 No.		
14	Sheet steel box of size 500mm x 500mm x 200mm with door including painting for mounting components at surface transformer with PVC conduit pipe for ducting.	01 Set.		
15	Installation, testing & commissioning.	01 Set.		

Area Manager (E&M)
Kusunda Area.

ANNEXURE-IV

For supply & installation of graded Electronic Earth Leakage Relay on 01 No 550 Volt ACB/Starter/G.E. Box of 26 No. seam , Godhur Colliery, Kusunda Area.

Sl. No.	Description	Qty.	Unit Rate	Total Amount
01.	Electronic Earth Leakage Relay of range 50 to 750 MA with time setting at 100 M.Sec. to 1.0 Sec. having Aux. supply 12V. to 550 Volt & NO + NC.	01 No.		
02.	CBCT Moulded Rasin cast for above Electronic Earth Leakage Relay suitable for 550 volt application.	01 No.		
03.	Amperemeter with CT.	01 Set.		
04.	Test Reset knobs with contacts.	01 Set.		
05.	Indicating lamp with Bulb & Holder.	02 Sets.		
06.	Fuse base with carrier.	02 Sets.		
07.	Microswitch with duel point.	01 Set.		
08.	Service & Hardware Kit.	01 Set.		
09.	Installation, testing & commissioning.	01 No.		

Area Manager(E&M)
Kusunda Area.

BHARAT COKING COAL LIMITED
(A SUBSIDIARY OF COAL INDIA LIMITED)
OFFICE OF THE CHIEF GENERRAL MANAGER,
P.O.KUSUNDA (DHANBAD)

Ref.No.AVI/E&M/2010-11/

DATED 15.11.2010

To,
The General Manager (System)
BCCL, Koyla Bhawan.

Sub:- Submission of CD with tender document for Website publication.

Dear Sir,

Please find enclosed a tender notice with detail CD for websidte
Publication. Tender Notice No.BCCL/AVI/E&M/2010-11/1289 dated
15.11.2010.

Encl:- 7 pages with CD.

Yours faithfuyly,

Area Manager(E&M)
Kusunda Area.

BHARAT COKING COAL LIMITED
(A SUBSIDIARY OF COAL INDIA LIMITED)
OFFICE OF THE CHIEF GENERAL MANAGER,K/AREA
P.O.KUSUNDA(DHANBAD)

Ref.No.AVI/E&M/2010-11/

Dated 15.11.2010

To
The P.R.O.,
BCCL, Koyla Bhawan.

Sub:- Submission of tender notice paper for paper publication

Dear Sir,

Please find enclosed herewith a Tender Notice No.BCCL/AVI/E&M/
2010-11/1289 dated 15.11.2010 for publication in leading & local news
Paper.

Last date of issue tender paper is 29.11.2010
Tender opening date. 02.12.2010

Encl: as above.

Yours faithfully,

Area Manager(E&M)
Kusunda Area.